

## ADDENDUM TO RFB #18-01 DOCUMENTS

**REQUEST FOR BID:** RFB #18-01 Water and Wastewater Treatment Unit Price Chemical Bid

**ADDENDUM NO.** 3

**DATE:** May 15, 2017

To All Prospective Bidders:

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made a part of the bid documents. Please attach this addendum to the original documents in your possession. The original RFB documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum. Respondent shall take this Addendum into consideration when preparing and submitting its response. ***The bidder shall acknowledge receipt of any and all addenda, if any, listing the Addenda by number(s) and date(s) in their bid response.***

### Sodium Hypochlorite Specifications

**On page 37, Paragraph 1(c) Quality, please note strikethrough on “with a pH of 11.0 + 0.5”. It is no longer a requirement.**

1. Quality:

Sodium hypochlorite is used by the **Wastewater Treatment Plant** for the process of odor control, disinfection of reclaimed water and the **Water Treatment Plant**, City of Escondido (city) as a disinfectant for potable water. Sodium hypochlorite supplied to both treatment plants shall comply with the following:

- a. Bidder shall furnish and deliver a specified quantity of sodium hypochlorite (12.5% by weight).
- b. The product shall be registered with USEPA, have USDA approvals D2 and G4, meet ANSI/AWWA Standard B300-10, and meet FDA requirements of 21 CFR 178.1010. Sodium hypochlorite metal contents must not exceed three (3) PPM iron (soluble) and less than two (2) PPM (total) for copper, nickel, and manganese. ~~with a pH of 11.0 + 0.5.~~

### T-22 Filter Aid Specifications

**On page 46, Paragraph 3 Approved Product, please note correction of WE-888 as current product required.**

1. Approved Product:

Products other than the one listed below must be subjected to testing as approved by the Wastewater Treatment Plant (HARRF) with all results to the satisfaction of the City within the prior year.

Approved Products:

<u>Company Name</u>	<u>Product</u>	<u>Pounds</u>
Polydyne	WE-850 (coagulant)	100,000
Polydyne	<del>WE-880</del> WE-888 (flocculant)	20,000
ChemTreat	P8906L (coagulant)	100,000
ChemTreat	P832E (flocculant)	20,000

All other Terms and Conditions shall remain the same. Should you have any questions, please contact me via email at: [ytrabue@escondido.org](mailto:ytrabue@escondido.org).

Sincerely,

Yvonne Trabue  
Purchasing Supervisor