

ADDENDUM TO RFB #18-01 DOCUMENTS

REQUEST FOR BID: RFB #18-01 Water and Wastewater Treatment Unit Price Chemical Bid

ADDENDUM NO. 1

DATE: May 10, 2017

To All Prospective Bidders:

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made a part of the bid documents. Please attach this addendum to the original documents in your possession. The original RFB documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum. Respondent shall take this Addendum into consideration when preparing and submitting its response. ***The bidder shall acknowledge receipt of any and all addenda, if any, listing the Addenda by number(s) and date(s) in their bid response.***

On page 40, Paragraph 1 Quality (c), the highlighted sentence below was omitted from the original RFB.

BIOXIDE SPECIFICATIONS

1. Quality:

Bioxide (a registered trademark) is used by the **Wastewater Treatment Plant** pumping stations for hydrogen sulfide odor control and shall comply with the following:

- a. Bidder shall furnish and deliver a specified quantity of bioxide chemical.
- b. Bioxide chemical shall not contain any contaminants (metal content or other constituents that may harm or hinder wastewater treatment processes).
- c. The City does not own any storage, dosing or injection equipment required for the odor control chemical. **The City requires double-walled storage tanks to be provided for this product.** The successful bidder must provide any and all equipment required.
- d. If the bidder's product requires modification to the existing delivery system, the cost of designing and installing such modifications shall be included in the bid price.

All other Terms and Conditions shall remain the same. Should you have any questions, please contact me via email at: ytrabue@escondido.org.

Sincerely,

Yvonne Trabue
Purchasing Supervisor

