

ADDENDUM TO RFB #18-01 DOCUMENTS

REQUEST FOR BID: RFB #18-01 Water and Wastewater Treatment Unit Price Chemical Bid
ADDENDUM NO. 2
DATE: May 11, 2017

To All Prospective Bidders:

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made a part of the bid documents. Please attach this addendum to the original documents in your possession. The original RFB documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum. Respondent shall take this Addendum into consideration when preparing and submitting its response. ***The bidder shall acknowledge receipt of any and all addenda, if any, listing the Addenda by number(s) and date(s) in their bid response.***

On page 15, Paragraph 3 Product Requirements, the highlighted sentences below were omitted from the original RFB.

CATIONIC POLYMER SPECIFICATIONS

- Product Requirements:
The product supplied must be twenty percent (20%) solids with a specific gravity of approximately 1.031. The quantity required is estimated to be 162 tons delivered in shipments of approximately, but not to exceed, 4,000 gallons or 48,000 pounds.

The approved product is Polydyne C-308P. Products other than the approved product must be subjected to testing as approved by the Water Treatment Plant with all results to the satisfaction of the City within the prior year.

All other Terms and Conditions shall remain the same. Should you have any questions, please contact me via email at: ytrabue@escondido.org.

Sincerely,

Yvonne Trabue
Purchasing Supervisor