

DATE: 12-19-88

ENGINEERING

BUILDING

PIPE

POLICE

COMMUNITY SERVICES (Neal Oslas)

RECEIVED

DEC 20 1988

BUILDING DEPT.

TO: PLANNING DEPARTMENT, CURRENT PLANNING

SUBJECT: PUBLIC HEARING APPLICATION CASE NO: 88-122-Cup

ADDRESS OF PROPERTY: 1817 Avenida del Diablo

RELATED CASES: \_\_\_\_\_

HEARING DATE: 2-14-89

Please review the attached documents for development requirements and general concerns. Comments may be returned on the lower portion of this form. Lengthy or detailed comments should be submitted in separate sheets on legal size paper.

Comments must be returned by 12-27-88

Thank You, Sc

Bldg

PLANNING DEPARTMENT, CURRENT PLANNING

COMMENTS ON CASE NO: 88-122-Cup

No Comment -  
State of CA. preempts Building Dept.  
jurisdiction.

Down Mc Farland needs 30' separation since [unclear] on  
the corner the building 30' on fire [unclear] wall

Dan Faegan

(Name)

(Title)

ESCONDIDO  
RECEIVED  
DEC 20 1988  
PLANNING DEPT.