

DATE: 5-22-87

"PLEASE NOTE THAT THIS CASE HAS BEEN REVISED TO INCLUDE A 2000+ SQ. FT. BUILDING EXPANSION AS WELL AS A 33 SPACE PARKING LOT".

TO: ENGINEERING  
BUILDING  
FIRE  
POLICE

FROM: PLANNING DEPARTMENT, CURRENT PLANNING

SUBJECT: PUBLIC HEARING APPLICATION CASE NO: 87-36-CUP (REVISED)

ADDRESS OF PROPERTY: 1817 Avenida Del Diablo

RELATED CASES: \_\_\_\_\_

HEARING DATE: July 14, 1987

Please review the attached documents for development requirements and general concerns. Short comments may be returned on the lower portion of this form. Lengthy or detailed comments should be submitted in memo form on legal size paper.

Comments must be returned by 5-29-87

Thank You, Sue

FROM: Fire Dept.

TO: PLANNING DEPARTMENT, CURRENT PLANNING

SUBJECT: COMMENTS ON CASE NO: 87-36-CUP (REVISED)

The New Bldg is Required to Sprinkler

*Cris Gibson*  
Chief

*Fire Marshal*  
Title

CITY OF ESCONDIDO  
RECEIVED  
MAY 28 1987  
PLANNING DEPT.