

**CITY OF ESCONDIDO
PLANNING DEPARTMENT**

To: ERNE

From: PATRICIA TORCHMANN

Subject: 96-123 CUP

Date: 10/24/86

Ernie -

There are 2 fire hydrants on the site, but curbs are not painted red - should curbs be painted red? If so, what length of curb needs to be red?

I need to know so we can figure out amount of on-street parking which is available for the stay report - Thanks -

*per Ernie,
curbs do not need
to be painted red
because parking
is restricted
for 15' on each
side of the
hydrant.*

100 VALLEY BLVD., ESCONDIDO, CA 92025

(714) 741-4671