

City of Escondido

2010 Consumer Confidence Report



The City of Escondido Utilities Department (City) is pleased to provide you with this year's Consumer Confidence Report. This report is to inform you about the quality of water that is delivered to you every day. **During 2010, the City of Escondido's drinking water met or exceeded all state and federal government drinking water standards.**

Over the many years that the City and the Rincon del Diablo Municipal Water District (Rincon) have served the greater Escondido community, geographic characteristics of the area have led to unique agency boundaries. With existing water exchange agreements between the two agencies, some customers of one agency may be provided water originating from the other. This report focuses on water received from the City of Escondido. Those customers serviced by Rincon will receive a Consumer Confidence Report directly from that agency. If you have any questions regarding your water source, please contact the agency that regularly bills you for water service.

Where Does My Water Come From?

The City of Escondido uses two sources for drinking water. The first is local water, which originates from the watershed and well fields near Lake Henshaw. This water is transferred to Lake Wohlford via an open canal. The City prepared a Sanitary Survey Update of the local watershed in 2005. A copy of the Watershed Sanitary Survey is available for review online at the California Department of Public Health website: www.cdph.ca.gov. While the survey identifies a number of activities that have the potential to adversely affect water quality, including residential septic facilities, urban runoff, and agricultural and recreational activities, no contaminants from these activities were detected in the local water supply.

The second source is water purchased from the San Diego County Water Authority (SDCWA) and imported from the Colorado River via the Colorado Aqueduct and from Northern California via the State Water Project. The Metropolitan Water District of Southern California (MWD) completed its Source Water Assessment (similar to the Watershed Sanitary Survey) of its Colorado River and State Water Project supplies in 2002. A copy of the assessment can be obtained by contacting MWD at (213) 217-6850 or online at www.mwdh2o.com.

All water, regardless of source, is treated at the Escondido-Vista Water Treatment Plant. The treatment of water includes filtration and disinfection to ensure destruction of harmful organisms. After chemical treatment and removal of organic components and suspended materials, the water is further filtered and is distributed from the Escondido-Vista Water Treatment Plant to the Vista Irrigation District and throughout Escondido via a system of pipelines and reservoirs.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien. Si tiene preguntas favor de llamar al número: (760) 839-4662.

(a) PARAMETER	Units	State MCL (MRDL)	PHG (MCLG) (MRDLG)	Range	Average	DLR	Typical Source / Comments
Clarity (Turbidity) (b), (c)							
Turbidity of Combined Filter Effluent in WTP (at 4 hour intervals)	NTU	TT = 1	NS	0.03 - 0.16	0.06	-	Soil runoff.
	%	95%(<0.3)		Highest NTU = 0.16	%(<0.3NTU) = 100 %		
Turbidity in Distribution System	NTU	5	(0)	0.05 - 0.53	0.13	-	Sediment in distribution system.
	%			% (<0.5NTU) = 99.9%			
Microbiological Contaminants (d), (e)							
Total Coliform Bacteria (Monthly) in Distribution System	%	5	(0)	0 - 2.01	0.27	-	Naturally present in the environment.
				Monthly Highest = 2.01.%			
Heterotrophic Plate Count Bacteria in Distribution System	CFU/mL	500	NS	< 1 - 720	7	-	Naturally present in the environment.
	%	95% (<500)		% (<500 CFU/ml) = 99.8%			
Heterotrophic Plate Count Bacteria in EPTD	CFU/mL	500	NS	< 1 - 15	0.6	-	Naturally present in the environment.
Disinfectants / Disinfection Byproducts in the Distribution System							
Total Trihalomethanes (TTHMs) Running Annual Average(RAA) Highest Annual Running Ave.	ug/L	80	NS	42 - 58	48	1	Byproducts of drinking water chlorination; sampled quarterly in distribution system. (f)
				46 - 50	47		
					50		
Haloacetic Acids (HAA5) Running Annual Average(RAA) Highest Running Annual Ave.	ug/L	60	NS	11 - 30	18	1	Byproducts of drinking water chlorination; sampled quarterly in distribution system. (g)
				16 - 20	18		
					20		
Total Chlorine Residual (Cl2) Running Annual Average(RAA) Highest Running Annual Ave.	mg/L	[4.0]	[4.0]	0.1 - 3.4	2.0	-	Addition of chlorine and ammonia (chloramine) as a combined disinfectant. Calculated quarterly with monthly average values.
				2.0 - 2.0	2.0		
					2.0		
Chlorite (ClO2-) Monthly Average	mg/L	1	(0.8)	0.50 - 0.64	0.59	0.02	Byproducts of drinking water chlorination. Monitored during pre-chlorination with chlorine dioxide.
				0.52 - 0.63	0.59		
Chlorate (ClO3-) Monthly Average	ug/L	(NL=800)	NS	150 - 310	210	20	Byproducts of drinking water chlorination. Monitored during pre-chlorination with chlorine dioxide.
				160 - 300	210		
PARAMETER	Units	State AL (h)	PHG	90th Percentile of 64 Samples	# of Sites > AL	DLR	Typical Source / Comments
Inorganic Contaminants - Copper / Lead in Residential Taps (Sampled in Year 2009) (i)							
Copper (Cu)	mg/L	1.3	0.17	0.62	0	0.05	Corrosion of household plumbing systems. Sampled in year 2009.
Lead (Pb)	ug/L	15	2	< 5	0	5	Corrosion of household plumbing systems; erosion of natural deposits. Sampled in year 2009.
PARAMETER	Units	State MCL	PHG (MCLG)	Range	Average	DLR	Typical Source / Comments
Inorganic Contaminants - Primary Standards (Finished Water)							
Barium (Ba)	mg/L	1	2	ND - 0.11	ND	0.1	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits.
Fluoride (F)	mg/L	2	1	0.77 - 0.81	0.79	0.1	Erosion of natural deposits; adding fluoride helps prevent dental caries in consumers. (Control Range: 0.7 - 1.3 ppm)
Inorganic Contaminants - Secondary Standards (Finished Water)							
Color	Units	15	NS	1 - 1	1	-	Decaying vegetation or other naturally occurring organic materials.
Chloride (Cl-)	mg/L	500	NS	60 - 87	78	-	Runoff/leaching from natural deposits; seawater influence.
Corrosivity	SI	Non-corrosive	NS	0.04 - 0.42	0.23	-	Natural or industrial-influenced balance of hydrogen, carbon & oxygen in the water; affected by temperature and other factors.
Foaming Agents(MBAS)	ug/L	500	NS	ND - 110	ND	50	Municipal and industrial waste discharge.
Sulfate (SO4)2-	mg/L	500	NS	130 - 200	170	0.5	Runoff/leaching from natural deposits; industrial wastes.
Total Dissolved Solids	mg/L	1000	NS	398 - 606	486	-	Runoff/leaching from natural deposits; industrial wastes.
Turbidity	NTU	5.0	NS	0.05 - 0.15	0.09	-	Soil runoff.
Specific conductance	umho/cm	1600	NS	668 - 980	799	-	Substances that form ions when in water; seawater influences.
Inorganic Contaminants - Unregulated (Finished Water)							
Boron	mg/L	(NL=1)	NS	0.13 - 0.14	0.14	0.1	State regulations requires us to monitor this contaminant while the State considers setting a limit on it.
Radionuclides Contaminants (Finished Water) - (Sampled in year 2008)							
Uranium	pCi/L	20	0.43	1.9 - 1.9	1.9	1	Erosion of natural deposits. Sampled in year 2008.
Additional Analyzed (Finished Water)							
Total Alkalinity as CaCO3	mg/L	NS	NS	100 - 120	108	-	Erosion of natural deposits; leaching.
Bicarbonate (HCO3)-	mg/L	NS	NS	122 - 146	131	-	Erosion of natural deposits; leaching.
pH	Units	6.5 - 8.5	NS	7.4 - 8.5	7.8	-	
Hardness as CaCO3	mg/L	NS	NS	150 - 240	203	-	Erosion of natural deposits; leaching.
Calcium (Ca)	mg/L	NS	NS	36 - 58	49	-	Erosion of natural deposits; leaching.
Magnesium (Mg)	mg/L	NS	NS	15 - 22	19	-	Erosion of natural deposits; leaching.
Sodium (Na)	mg/L	NS	NS	76 - 84	81	-	Erosion of natural deposits; leaching.
Potassium (K)	mg/L	NS	NS	4.0 - 4.8	4.3	-	Erosion of natural deposits; leaching.
Silica (SiO2)	mg/L	NS	NS	5.7 - 8.6	6.7	-	Erosion of natural deposits; leaching.
Total Chlorine Residual (Cl2)	mg/L	[4.0]	[4.0]	2.5 - 3.3	2.7	-	Addition of chlorine and ammonia (chloramine) as a combined disinfectant.
Total Trihalomethanes (TTHMs)	ug/L	80	NS	40 - 53	45	1	Byproducts of drinking water chlorination.
Haloacetic Acids (HAA5)	ug/L	60	NS	11 - 27	17	1	Byproducts of drinking water chlorination.
Chlorite (ClO2-) Monthly Average	mg/L	1	(0.8)	0.5 - 0.7	0.7	0.02	Byproducts of drinking water chlorination. Monitored during pre-chlorination with chlorine dioxide.
Chlorate (ClO3-) Monthly Average	ug/L	(NL=800)	NS	160 - 290	190	20	Byproducts of drinking water chlorination. Monitored during pre-chlorination with chlorine dioxide.
Total Organic Carbon(TOC)	mg/L	NS	NS	2.2 - 4.0	3.2	0.3	TOC provides a medium for the formation of disinfectant byproducts.These by-products include TTHMs and HAAs.

Notice – Sources of drinking water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water:

- ▣ **Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, pets, and wildlife.
- ▣ **Inorganic contaminants**, such as salts and metals that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- ▣ **Pesticides and herbicides**, which may come from a variety of sources like agriculture, urban stormwater runoff, and residential uses.
- ▣ **Organic chemical contaminants**, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- ▣ **Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

Potable Water

Since your water comes from a natural source and has met the federal and state standards, it is considered safe or “potable” (rhymes with floatable). In accordance with state regulations, your drinking water is routinely monitored for numerous contaminants. These contaminants include inorganic contaminants, lead, copper, nitrates, volatile contaminants, synthetic organic contaminants, disinfection by-products, and microbiological contaminants.

Water Fluoridation

The State of California requires that water agencies serving more than 10,000 customers fluoridate their drinking water supplies. Our water system treats your water by adding fluoride to the naturally occurring level in order to help prevent dental decay in consumers. The fluoride levels in the treated water are maintained within a range of 0.7-1.3 ppm as required by the California Department of Public Health.

EPA’s Safe Drinking Water Hotline

All drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants, and any potential health effects, are available from the [Safe Drinking Water Hotline at 1-800-426-4791](http://www.epa.gov/safewater) or online at www.epa.gov/safewater.

Foot Notes

- (a) **Data** shown are annual averages and ranges.
- (b) **Tests are performed on drinking water turbidity** (clarity) at the Water Treatment Plant and in the distribution system. The turbidity tests are done continuously at the WTP. In addition, samples are taken each week at various points in the distribution system. This table reflects the clarity or turbidity produced at the WTP and in the distribution system.
- (c) **The turbidity** level of the filtered water shall be less than or equal to 0.3 NTU in 95% of the measurements taken each month and shall not exceed 1.0 NTU at any time.
- (d) **Total coliform MCLs:** No more than 5% of the monthly samples may be total coliform positive.
- (e) **The City of Escondido Water Distribution System** consists of approximately 350 miles of pipelines. Tests are performed each week at various points along the system for compliance with bacteriological and physical parameters. Of concern to all customers is the bacteriological quality of the drinking water. The distribution system table indicates the amount of positive samples found in the system.
- (f) **Calculated** from the average of quarterly samples.
- (g) **Calculated** from the average of quarterly samples.
- (h) **The Federal and State standards** for lead and copper are treatment techniques requiring agencies to optimize corrosion control treatment. Average of the highest value is the 90th percentile value.
- (i) **This table shows the levels of copper and lead** found in the homes of selected customers. The Copper Lead Rule requires the collection of special samples from designated residents every three years. The amount of lead and copper found in the samples is an indication of the degree of leaching within the customer-owned copper plumbing and brass faucets. Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that your home’s level may be higher than at other homes in the community as a result of materials used in your home’s plumbing. If you are concerned about the elevated lead levels in your home’s water, you may wish to have your water tested. As a rule, flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the [Safe Drinking Water Hotline at \(800\) 426-4791](http://www.epa.gov/safewater) or online at www.epa.gov/safewater.

Abbreviations Key

AL	Regulatory Action Level: The concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.
CFU	Colony-Forming Units
DLR	Detection Limit for Reporting: A detected contaminant is any contaminant detected at or above its detection level for purposes of reporting.
DSYS	Distribution System.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to PHGs, MRDLGs, and maximum contaminant level goals as economically or technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the <i>United States Environmental Protection Agency</i> (US EPA).
mg/L	Milligrams Per Liter: Parts per million (ppm).
NA	Not Applicable.
ND	None Detected: Parameters for detection limits available upon request.
ng/L	Nanograms Per Liter: Parts per trillion (ppt).
NL	Notification Level.
NS	No Standard.
MRDL	Maximum Residual Disinfection Limit: The level of a disinfectant added for water treatment that may not be exceeded at the consumer’s tap.
MRDLG	Maximum Residual Disinfectant Level Goal: The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLs are set by the <i>United States Environmental Protection Agency</i> .
NTU	Nephelometric Turbidity Units: A measure of the cloudiness in water. It is a good indicator of the effectiveness of the WTP and DSYS.
pCi/L	PicoCuries Per Liter: A measure of radioactivity.
PDWS	Primary Drinking Water Standard: MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
PHG	Public Health Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the <i>California Environmental Protection Agency</i> .
SI	Saturation Index (Langelier).
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
ug/L	Micrograms Per Liter: Parts per billion (ppb).
Umho/cm	Micromhos Per Centimeter: A measure of a substance’s ability to convey electricity.
WTP	Water Treatment Plant.

For Volumetric Measurements used in this report, Please consider the following approximations for perspective purposes:

1 part per million = 1 packet of artificial sweetener added to 250 gallons of iced tea. **(mg/L)**

1 part per billion = 1 packet of artificial sweetener added to an Olympic size swimming pool. **(ug/L)**

1 part per trillion = 3 grains of artificial sweetener added to an Olympic size swimming pool. **(ng/L)**

If you have any questions regarding the water quality information in this report, please call Timothy Kwak, Supervising Chemist at 760-839-6274.

Utilities Department
201 North Broadway
Escondido, CA 92025

Postal Customer



B
E
F
O
R
E



California-friendly landscaping is an attractive alternative to unused lawns. Changing your style, like this Escondido homeowner, could save you water, money and time. Learn more at the Conservation page at www.escondido.org/utilities.aspx

Hard Water

Water is considered "hard" when two non-toxic minerals, calcium and magnesium, are present in water in substantial amounts. The term "hard" refers to the difficulty of getting soap to lather when used with this water. You may see the affects of hardness around your kitchen and bathrooms. Hardness is the cause for white scaling in tea kettles and on shower heads and faucets. In some instances, water-related appliances (e.g., dishwashers, water heaters, etc.) may be affected by the level of hardness. When this is the case, the manufacturer of the appliance may ask you to verify the level of hardness in your water. **In 2010, hardness ranged from 9 - 14 grains/gallon.**

Water Taste & Smell

When your water tastes or smells funny, the problem might be in the water or it might not. The odor may actually be coming from your sink drain where bacteria grow on food, soap, hair, and other things that get trapped. Gases in the drain that smell get stirred up when water goes down the pipe. Odor can also come from bacteria growing in water heaters—usually ones that have been turned off for a while or have the thermostat set too low.

Chlorine is added to tap water to ensure that germs in the water are killed. When you can taste or smell a hint of chlorine, your water has been properly treated. There are regulations that limit the amount of chlorine added to tap water. An easy way to get rid of chlorine taste and smell is to let the water sit in a glass for a few minutes or put the water in a covered container and chill it in the refrigerator.

For odor, does it come from only one faucet? Does it go away after running the water for a few minutes? If the answer is yes to either question, the source of the odor is probably within your plumbing system. If no to both questions, please call the Maintenance and Operations Division at 760-839-4668.

Get Involved

The City Council of the City of Escondido normally meets the first four Wednesdays of each month at 4:30 p.m. in the Council Chambers at City Hall. The address is 201 North Broadway, Escondido. Call 760-839-4638 or visit www.escondido.org for details.